

Ross Valley School District

Manor ES

Painting Project 1819-01

5-4-2018

(CUPCCAA)

Addenda 1

Questions and Answers

- | | |
|--|---|
| 1. Do we paint the murals | No, do not paint murals |
| 2. Do we need to open windows or paint shut | Open windows and paint inside |
| 3. Do we paint pipes that are on overhangs | Yes |
| 4. Do we remove staples | Yes |
| 5. Do we remove and replace coat hooks | Remove but do not replace |
| 6. Birds nest
existing birds nest. | Do not pressure wash, remove or paint |
| 7. Do we paint poles | Yes |
| 8. Do we paint benches | Yes |
| 9. Do we paint picnic tables | No |
| 10. Has there been a lead test
I get them I will send out | Yes, results are not back yet. As soon as |
| 11. Start and end date change | Start June 18/ End August 21 2018 |
| Other projects will be on site and some start and stop of project may happen | |
| 12. On the bid walk I forgot to enter and talk about restrooms. In the bid docs it does require painting 6 restroom, 2 of the restrooms have concrete floors that need to be scraped and painted. The floors and wall do not contain lead. | |
| END | |

Thank you



Bret Joyner